

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1130:226 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Honeywell International Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

DESIGN: Model XLS-524UD fire alarm control unit. Local and central station, noncoded, automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

XLS-524UD	Control Unit
RM-5F	Relay Module
ADM-24	Annunciator Driver
XRM-24	Transformer

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-0075:169

09-09-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**